

SHORT NOTICE INVITING TENDER

Sealed Bids are invited by Delhi & District Cricket Association (DDCA) situated at Arun Jaitley Stadium, Ferozshah Kotla, New Delhi – 110002 from the eligible OEMs / Authorized agency for the work as per Annexure-A below:

The bidder is required to give the following details:

Criteria	Supporting Compliance Documents
Name of the bidder and complete address	To be filled by the bidder
Legal Status (Individual, Sole Proprietary firm, Hindu Undivided Family (HUF) business, Partnership firm, Consortium, Joint Venture, Limited Company or Corporation)	To be filled by the bidder
GST Registration Certificate	Copy of Certificate to be enclosed
Proof of Site Inspection Prior to Submission	The Bidder must get Appendix-1 (Proof of site inspection prior to bid submission) Signed by the PMC DDCA. The Appendix -1 needs to be submitted along with the eligibility documents of the bid. The bid shall not be accepted if the signed Appendix-1 is not submitted.
The firm /applicant should not be blacklisted by any central Govt/ state Govt/ PSU/ Govt Bodies	Self- declaration certificate needs to be enclosed
The applicant should not be DDCA member/employee or the relative of DDCA member/employee	The applicant should give a self-declaration / affidavit.
Eligibility criteria: OEM/ Authorized agency of the OEM 1. OEM must be from the list of approved makes only (refer Annexure-A). 2. An OEM can authorize a single agency only (Bids shall not be accepted if multiple authorizations are issued).	Please enclose copy of authorization letter of OEM duly countersigned signed by applicant

EMD: Rs. 1 lac by way of a demand draft/ Bank Guarantee from a nationalized or commercial scheduled bank

INSTRUCTIONS TO THE APPLICANT

1. Please read the Terms & Conditions carefully before filling up the document.
2. Incomplete Documents will be rejected. It is in the interest of perspective applicants that they may inspect the proposed premises before submitting the bid and obtain the site inspection certificate as per Annexure-1 enclosed.
3. DDCA reserves the right to obtain feedback from the previous/present clients of the applicant and also depute its team(s) to inspect the site(s) at present contract(s) for on the spot first-hand information regarding the maintenance and other related services provided by the applicant. The decision of the DDCA in this regard will be final and binding on all bidders.
4. All statutory taxes/fees of any kind other than GST shall be borne by the applicant.
5. Work is to be completed before September 25, 2023.

Other Terms & Conditions:

- A. The necessary details / clarification if any can be obtained from DDCA Office.
- B. All quotations / offers/ Tenders should be on Company / Firms or Organisation LetterHead with logo.
- C. The payment for the goods supplied/services rendered by the applicant shall be made on completion of the goods supplied/services rendered.
- D. DDCA reserves its right to accept or reject any of the offers or cancel all offers and also modify conditions or effect any other change in items, terms and conditions.
- E. The sealed envelope containing quotations SUPERSCRIBED as “**SITC LED fittings at Arun Jaitley Stadium**” and addressed to Delhi & District Cricket Association, Arun Jaitley Stadium, Ferozshah Kotla Grounds, New Delhi-110002 may be dropped in a tender/quotation box kept in DDCA during office hours 10 A.M TO 5 P.M.
- F. **The bids must reach in the tender/quotation box of the DDCA by 26.08.2023 by 03.00P.M. Late tenders will not be accepted.**
- G. In the event another party is sought to be engaged as a supplier for the purposes of the quotation, this may only be done by obtaining consent in writing of the Authorized official of DDCA.
- H. All disputes shall be subject to the jurisdiction of courts of Delhi
- I. Please quote rates item wise in the same format as in Annexure-A else tender/quotation will be summarily rejected.

Tender & Purchase Committee.

Annexure - A
(BOQ)

Sl. No.	Description	Qty.	Unit	Rate	Amount
1.	Supply Installation Testing & Commissioning of 15W Recess Mounted Round Led Downlighter delivering minimum system lumen of 1500 lm & the luminaire shall be with system efficacy ≥ 100 lm / W, Cutout 150mm & Height 59mm (Tolerance +/- 2mm). CRCA Body and Pressure Die Cast Aluminium heat sink, Optics: HET PC Diffuser with deep inset of min 15mm. The operating CCT shall be 5700K with CRI of ≥ 80 . The luminaire shall be BIS Registered with electronic driver with input voltage range of 100 to 265V , THD $\leq 10\%$ & PF ≥ 0.95 , 50,000 Hrs LED Life with L70 Criteria. The LED Driver shall be easily available in India for repair and service. The LED shall be SMD type. Including dismantling of the existing old CFL 2x18 watt light fitting etc as required (Approved makes: Philips / Panasonic / Wipro)	650	Nos.		
2	Supply Installation Testing & Commissioning of LED Batten luminaire delivering an initial system lumen of 4000 lumens & the luminaire shall be with system efficacy ≥ 100 lm / W. The luminaire Housing shall be made of Co-extruded Polycarbonate & the diffuser shall be of polycarbonate. The operating CCT shall be 5700K with CRI of ≥ 80 . The luminaire shall be BIS Registered with electronic driver with input voltage range of 150 to 270V , THD $\leq 10\%$ & PF ≥ 0.9 , 50,000 Hrs LED Life with L70 Criteria, IP65. The LED Driver shall be easily available in India for repair and service. Luminaire shall have minimum surge protection of 3KV. Including dismantling of the existing old light fitting etc as required etc. as required. (Approved makes: Philips / Panasonic / Wipro)	50	Nos.		

3	<p>Supply Installation Testing & Commissioning of Recessed SMD LED 595mm X 595mm luminaire delivering an initial system lumen of 3600 lumens & the luminaire wattage is 36W. Housing: Powder coated CRCA Housing with Aluminum Frame, Optics: High Efficiency translucent diffuser for uniform light distribution without glare, and UGR<19. The operating CCT shall be 5700K with CRI of ≥80. The luminaire shall be BIS Registered with electronic driver with input voltage range of 150 to 270V , THD ≤ 10% & PF ≥ 0.95, 50,000 Hrs LED Life with L70 Criteria. The LED Driver shall be easily available in India for repair and service. Luminaire shall have minimum surge protection of 4KV. Including dismantling of the existing old light fitting etc as required etc. As reqd. (Approved makes: Philips / Panasonic / Wipro)</p>	180	Nos.		
4	<p>Supply Installation Testing & Commissioning of LED surface mounted IP66 LED fixture delivering an initial system lumen of 7000 lumens and consuming 55W & the luminaire shall be with system efficacy ≥ 127 lm / W. The luminaire Housing shall be made of Pressure Die Cast aluminium & diffuser with advanced Fresnel lens optical cover for uniform distribution. The operating CCT shall be 5700K with CRI of ≥70. The luminaire shall be BIS Registered with electronic driver with input voltage range of 150 to 270V, THD ≤ 10% & PF ≥ 0.95 , 100,000 Hrs LED Life with L70 Criteria, IP66. The LED Driver shall be easily available in India for repair and service. Luminaire shall have minimum surge protection of 4KV and 10KV external SPD. (Approved makes: Philips / Panasonic / Wipro)</p>	500	Nos.		

5	Supply Installation Testing & Commissioning of 30-35 W Surface Mounted IP65 LED Fixture delivering minimum system lumen of 3850 lm & the luminaire shall be with system efficacy ≥ 110 lm/W. Pressure Die Cast Aluminium housing & diffuser with advanced Fresnel Lens, Dimension (150mm X 150mm) & Height 116mm (Tolerance+/- 2mm). The operating CCT shall be 5700K with CRI of ≥ 70 . The luminaire shall be BIS Registered with electronic driver with input voltage range of 150-270V, THD $\leq 10\%$ & PF ≥ 0.95 , 100000 Hrs LED life with L70 Criteria. The LED driver shall be easily available in India for repair and service. The LED shall be SMD type. Including dismantling of the existing old CFL light fitting etc as required (Approved makes: Philips / Panasonic / Wipro).	600	Nos.		
6	Credit for Buy back of all the existing old light fitting dismantled in item No. 1 to 5 above on as is where basis.		LS		
TOTAL					

(Total amount In words Rs.----- only)

NOTE:

1. **The rates to be quoted without GST. GST shall be extra as applicable.**
2. **The onsite warranty shall for minimum 5 years. OEM warranty certificate to be submitted to DDCA soon after delivery but before start of installation at site.**
3. **DDCA reserves the right to demand any sample of the above item(s) for approval / technical bid evaluation.**
4. **The credit for the buyback towards the buyback price is to be quoted in item no 6 in the BOQ as lump sum (LS) amount and the buyback price is to be shown as minus amount in the BOQ. After depositing buyback amount by the bidder to DDCA, he may take out the dismantled items from the premises.**

(Signature of the bidder with seal)

APPENDIX -1
Site visit certificate

(Prior to date of bid submission)

Name of Work: **Supply Installation Testing & Commissioning LED Fittings at Arun Jaitley Stadium**

This is to certify that representatives of M/S visited Arun Jaitley Stadium, New Delhi on.....for ascertaining and analyzing the site conditions of the Stadium for participation in the quotation of the above work.

CE(E) DDCA/ PMC(E) DDCA