

Corrigendum to Tender Notice for “Conceptualize, Plan, Design, Supply, Installation, Testing and Commissioning of New Passenger Lifts for General stands, NCH, Service Lifts including Shaft Construction and Lift Controllers for Automated Access Control to various floors, QR scanner & Integration with ticking system at Arun Jaitley Stadium New Delhi ”

S. No	NIT Reference	Description as per NIT	Proposed amendment for Corrigendum
1	Pg 8, Section 5, Subsection E (v)	Construction of Lift well shall be RCC (all 3 sides shall be RCC) as per manufacturers standard & approved structural designer duly approval of structural details by OEM of Lift manufacturer & shaft should be as per Industry Standards, CPWD Specification, MCD, Delhi Fire service and Government norms.	Construction of Lift well shall be with bricks (all 3 sides shall be bricks; Columns and Beams shall be RCC) as per manufacturers standard & approved structural designer duly approval of structural details by OEM of Lift manufacturer & shaft should be as per Industry Standards, CPWD Specification, MCD, Delhi Fire service and Government norms .Provided proposed design will not affect the performance, durability and Life.
2	Pg 8, Section 5, Subsection E (ix)	All the items/materials required to complete the work should be included in BOQ. If any items required during execution of work within the scope of RFP even not mentioned in BOQ but the same shall have to be done without extra cost. However, in new requirement shall be done on prior approval of from DDCA.	No changes required as RFP is called for Concept ,plan and design by the Bidder themselves.
3	Pg 26, Annexure-A (Acceptable Makes of Materials)	Passenger and Service Lift: OTIS / Schneider / Mitsubishi	In the RFP we proposed only best 03 make Lifts .However Kone make may also be considered for better competition as Kone make lifts are also comes under same category .where as Johnson makes lifts is not at par with the quality and performance to the above proposed make OTIS / Schneider / Mitsubishi/KONE
4	Pg 2,5 &19 in the RFP	Bid Submission End date: 22/05/2024 Bid Opening Date: 22/05/2024	Bid Submission End Date : 27.05.2024
5	Pg 5,	EMD by way of Demand draft from a Nationalised or Scheduled Bank.	EMD by way of Demand draft/FDR from a nationalized or Scheduled Bank
6	Anywhere in the RFP	Integration with ticking system	Read as Integration with ticketing system

Other terms and condition shall remain same as per NIT / RFP

Tender & Purchase Committee
Date : 21st May 2024